

Table 1

WESTLANDS WATER DISTRICT

Distribution System Integration Program

**Non-Project Water - Drinking Water Standards
Triennial Analysis**

Revised April 16, 2019

<u>INORGANICS</u>		<u>SECONDARY STANDARDS</u>	
1. <u>Constituent</u>	<u>MCL</u>	2. <u>Constituent</u>	<u>CAL</u>
Aluminum	1000 µg/L	Chloride	600 mg/L
Arsenic	10 µg/L	Conductivity	2200 µmho/cm
Barium	1000 µg/L	Copper	1.0 mg/L
Cadmium	5 µg/L	Iron	.30 mg/L
Chromium	50 µg/L	Manganese	.05 mg/L
Fluoride	2 mg/L	Sulfate	600 mg/L
Lead	15 µg/L	Total Dissolved Solids	1500 mg/L
Mercury	2 µg/L	Zinc	5.0 mg/L
Nitrate	10 mg/L		
Selenium	50 µg /L		
Silver	0.1 mg/L		
<u>OTHER</u>			
3. Boron	2.0 mg/l		
<u>SEMIVOLATIVE ORGANICS</u>			
4. <u>EPA 504</u>	<u>MCL</u>	<u>EPA 508</u>	<u>MCL</u>
Dibromochloropropane (DBCP)	0.2 µg/L	Heptachlor	0.01 µg/L
Ethylene Dibromide (EDB)	.05 µg/L	Heptachlor Epoxide	0.01 µg/L
		Chlordane	0.1 µg/L
<u>EPA 505</u>			
Endrin	2 µg/L	<u>EPA 515.1</u>	
Lindane	0.2 µg/L	2,4-D	70 µg/L
Methoxychlor	30 µg/L	2,4,5-TP (Silvex)	50 µg/L
Toxaphene	3 µg/L		
<u>EPA 507</u>			
Atrazine	1 µg/L	<u>EPA 515.1</u>	
Simazine	4 µg/L	Bentazon	18 µg/L
Thiobencarb	70 µg/L	<u>EPA 531</u>	
Molinate	20 µg/L	Carbofuran	18 µg/L
		<u>EPA 547</u>	
		Glyphosate	700 µg/L
<u>RADIOLOGICAL</u>		<u>KEY FOR ABBREVIATED TERMS</u>	
	<u>MCL</u>	CAL:	Consumer Acceptance Limits
5. Gross Alpha	15 pCi/L	MCL:	Maximum Contaminant Level
		µg/L:	Micrograms Per Liter
		mg/L:	Milligrams Per Liter
		pCi/L:	Picocuries Per Liter