

**Table 2**

WESTLANDS WATER DISTRICT

Distribution System Integration Program

Compliance Analysis

Constituents	Maximum Contaminant Level (MCL)
Arsenic	10 µg/l
Selenium	50 µg/l
Manganese	.05 mg/l
Nitrate	10 mg/l
Chloride	600 mg/l
Sulfate	600 mg/l
Total Dissolved Solids	1,500 mg/l
Conductivity	2,200 µmho/cm
Boron	2 mg/l